

Pg - 4  
CI FIRE.

**WARANGAL MUNICIPAL CORPORATION  
WARANGAL**

From  
The Commissioner,  
Warangal Municipal Corporation,  
Warangal.

To  
The District Educational Officer,  
Warangal District,  
Warangal.

RC. No. 29917/WMC/FPW/SCHL/2012, Dt: 27-08-2012.

Sir,

Sub:- Warangal Municipal Corporation - Fire Prevention Wing - Issuance of Fire No Objection Certificate to St. Peters High School, Church Compound, Old Bus Depot Road, Hanamkonda Submitted - Reg.

- Ref: 1. Application of Secretary & Correspondent, St. Peters High School, Church Compound, Old Bus Depot Road, Hanamkonda.  
2. Inspection report of Officers of Fire Prevention Wing, WMC, Warangal Dt: 25-08-2012.  
3. Rc. No. 5041/B2/97, Dt: 12-03-2010 of Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad.  
4. Section 13(2) of Fire Services Act 1999.

The Officers of Fire Prevention Wing, Warangal Municipal Corporation have inspected the premises of the St. Peters High School, Church Compound, Old Bus Depot Road, Hanamkonda, on 24-08-2012 and submitted the report vide reference 2<sup>nd</sup> cited.

2. The Management has constructed the Non Multi storied existing School Building with Ground + 2 Upper Floors with a height of 09 mtrs for Educational occupancy (B2) and submitted application for issuance of Fire "No Objection Certificate" for the above building,

**3 Particulars of the Building**

- a) Address of the Building : St. Peters High School,  
Church Compound, H. No. 2-6-1133,  
Old Bus Depot Road,  
Hanamkonda.
- b) Area of the Plot/Ht. of Buildings : 1500 Sq. mtrs / 09 mtrs
- c) No. of Blocks / Floor : One Block / G + 2 Upper Floors
- d) Type of occupancy : Educational Building (B2)
- e) Floor wise details : Given Below

Sl. No.	Floor	Area in Sq. mtrs	Occupancy	Occupant load
1	Ground	528.00	Educational Occupancy	132 Persons
2	First Floor	528.00	Educational Occupancy	132 Persons
3	Second Floor	528.00	Educational Occupancy	132 Persons
	Total	1584.00 Sq. mtrs		

4. The Management has provided one internal stair case with a width of 1.55 mtrs.

5. The Following Fire Safety measure are provided as per table - 23 part IV of NBC of India 2005.

Sl. No.	Fire Safety Measures	Required as per Table 23 Part - IV, of NBC Of India 2005	Provided	Deficit
1	Fire Buckets with Sand 09 Ltrs	04 Nos	04 Nos	Nil
2	Fire Extinguishers Water Expellant type	02 No's each Floor	02 No's each Floor	Nil
	b) CO2 4.5 Kg Capacity	02 Nos	02 Nos	Nil
3	Hose Reel	01 No in each Floor	01 No in each Floor	Nil
4	Over Head Tank	5000 Ltrs capacity	5000 ltrs capacity	Nil
5	One Booster Pump	450 LPM capacity	450 LPM Capacity	Nil

**PRINCIPAL**  
ST. PETERS HIGH SCHOOL  
Church Compound, Old Bus Depot,  
Hanamkonda.

**Secretary & Correspondent**  
**J.M.J. Educational Society**  
HANAMKONDA.